

Bus gateway BGW14



Only skilled electricians may install this electrical equipment otherwise there is the risk of fire or electric shock!

Temperature at mounting location:
-20°C up to +50°C.
Storage temperature: -25°C up to +70°C.
Relative humidity:
annual average value <75%.

RS485 bus gateway. Bidirektional. Bidirectional. Only 0.3 watt standby loss. Modular device for DIN-EN 60715 TH35 rail mounting. 1 module = 18 mm wide, 58 mm deep.

Connection to the Eltako-RS485 bus. Bus cross wiring and power supply with jumper.

Operation in conjunction with FAM14 or FTS14KS.

The Hold terminal is connected to the FAM14 or the FTS14KS.

Up to 16 sensors, e.g. BUTH65D/12V DC, BBH65/12V DC and BTR65H/12V DC can be connected to the RSA/RSB terminals. Data transmission and power supply takes place over the 4-wire bus with a 12V DC power supply unit. Standard telephone wire is sufficient as connecting lead: (J-Y (ST) Y 2x2x0,8 mm²) or equivalent.

The permitted maximum line length is 1000m. The second 120Ω terminal resistor must also be connected to the RSA/RSB terminals of the remotest sensor.

With up to 8 BGW14 devices, the data of up to 128 sensors can be fed to the RS485 bus.

The **operating mode rotary switch BA** of each BGW14 device must be set to a different position.

Bus output ID at Pos. 1 =
0x1900+sensor address

Bus output ID at Pos. 2 =
0x1920+sensor address

Bus output ID at Pos. 3 =
0x1940+sensor address

..

Bus output ID at Pos. 8 =
0x19E0+sensor address

The BGW14 queries all connected sensors cyclically and the sensors reply with a data telegram. The data is compared with the previous data and the data is only output to the RS485 bus if there is a change. If data is recurring, the connected sensors output status telegrams cyclically every 5 minutes.

The green LED lights up continuously when a connection to the FAM14 or FTS14KS is set up with PCT14 and lights up briefly when data is output to the RS485 bus.

Must be kept for later use!

We recommend the housing for operating instructions GBA14.

Eltako GmbH

D-70736 Fellbach

Technical Support English:

☎ Michael Thünte +49 176 13582514

✉ thuente@eltako.de

☎ Marc Peter +49 173 3180368

✉ marc.peter@eltako.de

eltako.com